



Asseverazione dei fattori di conversione in energia primaria dell'energia termica

Affidavit of conversion factors in primary thermal generation

Si dichiara che i fattori di conversione in energia primaria di:

We hereby declare that the primary energy conversion factors of:

Unità operativa:

Operative units:

Sono stati calcolati secondo le disposizioni del Decreto Interministeriale del 26 giugno 2015 e della norma UNI EN 15316:2018:

Are been calculated in according to the provisions of Ministerial Decree of June 26, 2015 and by the standard UNI EN 15316:2018:

ZOLA PREDOSA TELERISCALDAMENTO SRL

PIAZZA BENVENUTI 11 - 26013 CREMA (CR)

RETE DI TELERISCALDAMENTO DI ZOLA PREDOSA

VIA DELLO SPORT 101/103 - 40069 ZOLA PREDOSA (BO)

Asseverazione dei fattori di conversione in energia primaria dell'energia termica calcolati secondo il metodo indicato dalla norma UNI EN 15316:2018: «Prestazione energetica degli edifici - Metodo per il calcolo delle richieste di energia e delle efficienze del sistema»

Affidavit of conversion factors in primary thermal generation calculated in according to the method indicated by standard UNI EN 15316:2018 "Energy performance of buildings -Method for calculation of system energy requirements and system efficiencies"

SONO PARI A / AMOUNTING TO

fP,nren = 0,873 fP,ren = 0,359 fP,tot = 1,232

04 | 05 | 2020

Prima emissione
First certification

Flavio Ornago

Business Unit Management Systems Director